



**Instytut
Energetyki**

**INSTITUTE OF POWER ENGINEERING
– NATIONAL RESEARCH INSTITUTE**
Certification and Inspection Department
Mory 8, 01-330 Warsaw
phone +48 22 34 51 200
instytut.energetyki@ien.com.pl



AC 117

CERTIFICATE OF CONFORMITY

No. DZC.522.99.1.2025

Issue No. 01 of 2025.09.05

*Name and address of
the certificate holder:*

**PROTEKTEL Sp. z o.o.
ul. Pilsudskiego 92
06-300 Przasnysz**

Name of the product:

Surge arresters without gaps

Type:

PROXAR-IVN AC

Manufacturer:

**PROTEKTEL Sp. z o.o.
ul. Pilsudskiego 92
06-300 Przasnysz**

Parameters:

According to appendix

*The product meets
requirements of:*

IEC 60099-4:2014 (ed. 3.0)

*According to the
report made by:*

Institute of Power Engineering - National Research Institute

*Number of the evaluation
report:*

DZC.522.99.1.2025

Period of validity:

from 05th of September 2025 until 04th of September 2028

The right to use the certificate of conformity within its validity period applies only to:

- those copies that have the features, construction and equipment as the product samples submitted for testing
- certificate holder or his authorized representative

The list of technical data is included in the appendices to the certificate of conformity.

Number of appendices: 1

THE SYSTEM OF PRODUCT CERTIFICATION PC_1a (Program 1a acc. to PN-EN ISO/IEC 17067:2014-01)
(product parameters confirmed by type test)



DEPUTY DIRECTOR OF
INSTITUTE OF POWER ENGINEERING
– NATIONAL RESEARCH INSTITUTE

Prof. Grzegorz Tchorek, DSc, PhD

Warsaw, 2025.09.05

APPENDIX TO THE CERTIFICATE OF CONFORMITY

No. DZC.522.99.1.2025

Issue No. 01 of 2025.09.05

LIST OF EVIDENCED PARAMETERS OF THE PRODUCT

Rated voltage [U_r]	1 kV ÷ 120 kV
Continuous operating voltage [U_c]	0,8 kV ÷ 96 kV
Residual voltage at nominal discharge current [U_{res}]	2,6 kV ÷ 311 kV
Reduced voltage at switching impulse current [U_{ps}]	2,2 kV ÷ 258 kV
Nominal discharge current [I_n] (8/20 μ s)	20 kA
Switching current impulse (30/60 μ s)	2 kA
Discharge current withstand strength:	
- high current impulse (4/10 μ s)	100 kA
- long-duration current impulse in 2 ms (based on Q_{rs})	1100 A
Short-circuit withstand current (0,2 s)	65 kA
Rated repetitive charge transfer rating [Q_{rs}]	2,4 C
Rated thermal energy [W_{th}]	12 kJ/kV (U_r)
Single impulse energy capability (virtual impulse duration: 2 ÷ 4 ms) applied in Q_{rs} verification test	6,5 kJ/kV (U_r)
Class and designation of the arrester	station – SH
Partial discharge level at $1,05 \times U_c$	$\ll 10$ pC ¹⁾
Mechanical endurance:	
- 1000 cycles (SLL)	6000 Nm
- bending moment (SSL)	2400 Nm
Mechanical strength against torsional load	200 Nm
Power-frequency versus time characteristic (TOV)	positive result
1000 h weather ageing:	
- in salt mist	positive result
- resistance of the housing material to UV radiation	positive result

NOTES: -

¹⁾During the initial measurements in the type tests, the results were less than 5 pC.

